

# Township of Falls

188 Lincoln Highway, Suite 100  
Fairless Hills, PA 19030  
(215)-949-9000

E-Mail: [admin@fallstwp.org](mailto:admin@fallstwp.org)  
Website: [www.fallstwp.com](http://www.fallstwp.com)

August 1, 2017

Marcel L. Groen, Esquire  
Fox Rothschild, LLP  
10 Sentry Parkway, Suite 200  
P.O. Box 3001  
Blue Bell, PA 19422-3001

Re: Elcon Recycling Services, LLC zoning letter of consistency.

Dear Mr. Groen:

The requested signed and dated zoning consistency letter is enclosed.

Sincerely,

Thomas A. Hennett, CFM  
188 Lincoln Highway, Suite 100  
Fairless Hills, PA 19030  
215-949-9000 x 251  
[thennett@fallstwp.org](mailto:thennett@fallstwp.org)



Is there a legal challenge by the applicant with regard to zoning for the proposed project?

NO

Name and Contact Information for Municipal Zoning Officer:

Tom Bennett, Chief Code Enforcement Officer / Zoning Officer

188 Lincoln Highway, Suite 100

Fairless Hills, PA 19030

Additional Comments (attach additional sheets if necessary):

Submitted By:

Name	Tom Bennett
Title	Chief Code Enforcement Officer / Zoning Officer
Contact Information (Address & Phone)	188 Lincoln Highway, Suite 100 Fairless Hills, PA 19030 (215) 949-9000, Ext. 251
Signature	<i>Tom Bennett</i>
Date	8-1-17



**ATTACHMENT A1-2**  
**ARMY CORPS JURISDICTIONAL DETERMINATION**



REPLY TO  
ATTENTION OF

## DEPARTMENT OF THE ARMY

PHILADELPHIA DISTRICT CORPS OF ENGINEERS  
WANAMAKER BUILDING, 100 PENN SQUARE EAST  
PHILADELPHIA, PENNSYLVANIA 19107-3390

JAN 05 2015

Regulatory Branch  
Application Section I

SUBJECT: CENAP-OP-R 2014-1004-39 (Preliminary JD)  
Project Name: Elcon Recycling Services  
Latitude and Longitude: 40.168° N/-74.761° W

Zvi Elgat  
Elcon Recycling Services  
11 LeParc Drive  
Princeton, New Jersey 08550

Dear Mr. Elgat:

This letter is written with regard to your request for verification of a preliminary jurisdictional determination. The property associated with your request is located at, Tax Parcel Number 13-51-1-5 adjacent to Dan Sievers Place AKA Kuehn Circle, in Falls Township, Bucks County, Pennsylvania.

Pursuant to Section 10 of the Rivers and Harbors Act and Section 404 of the Clean Water Act, a Department of the Army permit is required for work or structures in navigable waters of the United States and the discharge of dredged and/or fill material into waters of the United States, including adjacent and isolated wetlands. Any proposal to perform the above activities within any waters of the United States, including wetlands, requires the prior approval of this office.

The plans identified on the following page depict all delineated waters and wetlands on the subject site that may be jurisdictional under Section 10 of the Rivers and Harbor Act and/or Section 404 of the Clean Water Act. This preliminary determination has been conducted to identify the location(s) of waters and wetlands that may be waters of the United States for the particular site identified in this request. This determination may not be valid for the wetland conservation provisions of the Food Security Act of 1985, as amended. If you or your tenant are U.S. Department of Agriculture (USDA) program participants, or anticipate participating in USDA programs, you should request a certified wetland determination from the local office of the Natural Resources Conservation Service prior to starting work.


This preliminary jurisdictional determination is non-binding and indicates that there may be waters of the United States, including wetlands, on the parcel. Preliminary JDs are advisory in nature and may not be appealed (See attached Notification of Appeal Form (Enclosure 1)); however, the applicant retains the right to request an approved Jurisdictional Determination, which may be appealed, for the site. Also enclosed (Enclosure 2) is a copy of the Preliminary

Jurisdictional Determination Form signed by the applicant or his agent agreeing to accept a preliminary jurisdictional determination. Please be aware that for purposes of computation of impacts, compensatory mitigation requirements, and other resource protection measures, a permit decision made on the basis of a preliminary JD will treat all waters and wetlands that would be affected in any way by the permitted activity on the site as if they are jurisdictional waters of the U.S.

This letter is valid for a period of five (5) years. This preliminary jurisdictional determination is issued in accordance with current Federal regulations and is based upon the existing site conditions and information provided by you in your application. This office reserves the right to reevaluate and modify the preliminary jurisdictional determination at any time should existing site conditions or Federal regulations change, or should the information provided by you prove to be false, incomplete, or inaccurate.

If you have any questions regarding this matter, please contact Mr. Lawrence Slavitter at (215) 656-6734 or write to the above address.

Sincerely,



Lawrence M. Slavitter  
Biologist

\*\*\*\*\*

**SUBJECT PROPERTY:** Elcon Recycling Services; 32 acres; Tax Map Parcel Number 13-51-1-5; adjacent to Dan Sievers Place (AKA Kuehn Circle, in Falls Township, Bucks County, Pennsylvania.

\*\*\*\*\*

**SURVEY DESCRIPTION:** Plot plan prepared by Gilmore and Associates, Incorporated, entitled "ALTA/ACSM Land Title Survey..."; dated March 28, 2014; last revised November 14, 2014, scale 1" = 50'; sheet 1 of 1.

\*\*\*\*\*

**COMMENTS:** Site inspection by representative of this office on November 14, 2014.

\*\*\*\*\*


Enclosures

**Copies Furnished:**

**PADEP, SE Regional Office (Norristown, PA)  
Bucks County Conservation District**

**Scott Bush**

**Conestoga-Rovers & Associates, Inc.  
410 Eagleview Boulevard Suite 110  
Exton, Pennsylvania 19341**



April 17, 2019



E-MAIL

Mr. Erik Garton, P.E.  
Vice President, Municipal Services Manager  
Gilmore & Associates, Inc.  
65 E. Butler Avenue, Suite 100  
New Britain, PA 18901

Subject: Sanitary Sewer and Water Service Calculations  
Elcon Recycling, Falls Township, Pennsylvania, Facility  
IES Project No. EG181065.02

Dear Erik:

Please find attached the calculation sheets for the estimated sanitary sewer and water service to the buildings at the proposed Elcon Recycling facility in Falls Township, Pennsylvania. The calculations are based on the preliminary architectural programming. The sanitary sewer service demand is estimated to be approximately 4,900 gpd. The water service demand to the buildings is estimated to be approximately 4,700 gpd. In addition, there will be an estimated 40,000 gpd water demand to support the process, primarily for steam generation. This results in a total estimate of 44,700 gpd fresh water demand for the site.

Please do not hesitate to contact me if you have any questions.

Very truly yours,

*James R. Rutenbar /e/*

James R. Rutenbar, P.E., LEED AP  
Director,  
Engineering and Construction

Attachments

cc: Z. Elgat, Elcon  
M. Fitzpatrick, IES  
A. Soni, IES



Job Number & Name	Calc By	Chkd By
Elcon Recycling - 18307	RR	RR
Description		Date
Building Sanitary Waste Demand		04/15/19

The site sanitary waste water demand shall be determined by calculating the following: The total number of occupants (total site population), mechanical waste and or floor drain waste demands, and Mechanical Equipment.

**Office Building:**

	Miscellaneous Equipment	Assumed Visitor Population	Programmed Building Population		Gallons per Day per Person (see note # 1)	=	Total Gallons per Day
Visitor Population		8		x	20	=	160
Building Population			30	x	20	=	600
Ice machine in refrigerators	1			x	0.5	=	1
Mothers Room	1			x	5	=	5
<b>SUB-TOTAL GALLONS</b>						=	<b>766</b>

**Maintenance Building:**

	Miscellaneous Equipment	Programmed Building Population		Gallons per Day per Person (see note # 1)	=	Total Gallons per Day
Building Population		20	x	20	=	400
Wash hose station	1		x	7	=	7
Combo Emergency/eyewsh Shower	1		x	300	=	300
<b>SUB-TOTAL GALLONS</b>					=	<b>707</b>

**Utilities Building:**

	Miscellaneous Equipment	Programmed Building Population		Gallons per Day per Person (see note # 1)	=	Total Gallons per Day
Building Population		40	x	20	=	800
Wash hose station	1		x	7	=	7
Combo Emergency/eyewsh Shower	1		x	300	=	300
<b>SUB-TOTAL GALLONS</b>					=	<b>1,107</b>



**Production Plant:**

	Miscellaneous Equipment	Programmed Building Population		Gallons per Day per Person (see note # 1)	=	Total Gallons per Day
Building Population		30	x	20	=	600
Wash hose station	1		x	7	=	7
Combo Emergency/eyewsh Shower	1		x	300	=	300
Ice machine in refrigerators	1		x	0.5	=	1
<b>SUB-TOTAL GALLONS</b>					=	<b>908</b>

**Production Warehouse:**

	Miscellaneous Equipment	Programmed Building Population		Gallons per Day per Person (see note # 1)	=	Total Gallons per Day
Building Population		15	x	20	=	300
Wash hose station	1		x	7	=	7
Combo Emergency/eyewsh Shower	1		x	300	=	300
<b>SUB-TOTAL GALLONS</b>					=	<b>607</b>

**Lab and Break Room:**

	Miscellaneous Equipment	Assumed Visitor Population	Programmed Building Population		Gallons per Day per Person (see note # 1)	=	Total Gallons per Day	
Visitor Population		4		x	20	=	80	
Building Population			20	x	20	=	400	
Wash hose station	1			x	7	=	7	
Combo Emergency/eyewsh Shower	1			x	300	=	300	
<b>SUB-TOTAL GALLONS</b>							=	<b>787</b>

Office Building						=	766
Maintenance Building						=	707
Utilities Building						=	1,107
Production Plant						=	908
Production Warehouse						=	607
Lab and Break Room						=	787
<b>TOTAL</b>						=	<b>4,881</b>

**Sub-Total Building Sanitary Waste Water Loads:** = 4,881

					<b>Total Gallons per Day</b>	=	<b>4,881</b>
4,881	Ga's /Day	x	30 Days			=	146,430
					<b>Total Gallons per Month</b>	=	<b>146,430</b>
146,430	Ga's /Day	x	12 Months			=	1,757,160
					<b>Total Gallons per Year</b>	=	<b>1,757,160</b>

**Notes:**

1. Refer to EPA "Manual of Individual Water Supply Systems" planning guide for water use values provided for gallons per day per person (GPD/Person).



Job Number & Name	Calc By	Chkd By
Elcon Recycling - 18307	RR	RR
Description		Date
Building Water Demand		04/15/19

The site water demand shall be determined by calculating the following: The total number of occupants (total site population), Mechanical cooling make-up water demands, and Mechanical Equipment.

**Office Building:**

	Miscellaneous Equipment	Assumed Visitor Population	Programmed Building Population		Gallons per Day per Person (see note # 2)	=	Total Gallons per Day
Visitor Population		8		x	15	=	120
Building Population			30	x	15	=	450
Ice machine in refrigerators	1			x	5	=	5
Mothers Room	1			x	5	=	5
Mechanical make-up water	1			x	25	=	25
<b>SUB-TOTAL GALLONS</b>						=	<b>605</b>

**Maintenance Building:**

	Miscellaneous Equipment	Programmed Building Population		Gallons per Day per Person (see note # 2)	=	Total Gallons per Day
Building Population		20	x	15	=	300
Wash hose station	1		x	7	=	7
Mechanical make-up water	1		x	3	=	3
Combo Emergency/eyewsh Shower	1		x	300	=	300
<b>SUB-TOTAL GALLONS</b>					=	<b>610</b>

**Utilities Building:**

	Miscellaneous Equipment	Programmed Building Population		Gallons per Day per Person (see note # 2)	=	Total Gallons per Day
Building Population		40	x	15	=	600
Wash hose station	1		x	7	=	7
Mechanical make-up water	1		x	50	=	50
Combo Emergency/eyewsh Shower	1		x	300	=	300
<b>SUB-TOTAL GALLONS</b>					=	<b>957</b>

**Production Plant:**

	Miscellaneous Equipment	Programmed Building Population		Gallons per Day per Person (see note # 2)	=	Total Gallons per Day
Building Population		30	x	15	=	450
Wash hose station	1		x	7	=	7
Mechanical make-up water	1		x	50	=	50
Combo Emergency/eyewsh Shower	1		x	300	=	300
Ice machine in refrigerators	1		x	5	=	5
<b>SUB-TOTAL GALLONS</b>					=	<b>812</b>

**Production Warehouse:**

	Miscellaneous Equipment	Programmed Building Population		Gallons per Day per Person (see note # 2)	=	Total Gallons per Day
Building Population		15	x	15	=	225
Wash hose station	1		x	7	=	7
Mechanical make-up water	1		x	25	=	25
Combo Emergency/eyewsh Shower	1		x	300	=	300
<b>SUB-TOTAL GALLONS</b>					=	<b>557</b>

**Lab and Break Room:**

	Miscellaneous Equipment	Assumed Visitor Population	Programmed Building Population		Gallons per Day per Person (see note # 2)	=	Total Gallons per Day	
Visitor Population		4		x	15	=	60	
Building Population			20	x	15	=	300	
Wash hose station	1			x	7	=	7	
Mechanical make-up water	1			x	25	=	25	
Combo Emergency/eyewsh Shov	1			x	300	=	300	
<b>SUB-TOTAL GALLONS</b>							=	<b>692</b>

Office Building						=	605
Maintenance Building						=	610
Utilities Building						=	957
Production Plant						=	812
Production Warehouse						=	557
Lab and Break Room						=	692
<b>TOTAL</b>						=	<b>4,233</b>

**Safety Factor:**

Safety Factor for Miscellaneous water consumption (see note # 1)

		4,233 Gal's /Day		x	0.10	=	423.3	
<b>SUB-TOTAL</b>							=	<b>423.3</b>

**Sub-Total Building Water Loads:**

**Safety Factor:**

					<b>Total Gallons per Day</b>	=	<b>4,656</b>	
4,656	Gal's /Day		x	30 Days		=	139,689	
<b>Total Gallons per Month</b>							=	<b>139,689</b>
139,689	Gal's /Day		x	12 Months		=	1,676,268	
<b>Total Gallons per Year</b>							=	<b>1,676,268</b>


**Notes:**

1. Safety Factor shall equate to 10% of the site total daily water consumption plus HVAC peak cooling load.
2. Refer to EPA "Manual of Individual Water Supply Systems" planning guide for water use values provided for gallons per day per person (GPD/Person).



1720 Walton Road, Blue Bell, PA 19422 610-828-3078 Fax 610-828-7842

April 17, 2019



E-MAIL

Mr. Erik Garton, P.E.  
Vice President, Municipal Services Manager  
Gilmore & Associates, Inc.  
65 E. Butler Avenue, Suite 100  
New Britain, PA 18901

Subject: Fire Suppression System Calculations  
Elcon Recycling, Falls Township, Pennsylvania, Facility  
IES Project No. EG181065.02

Dear Erik:

Please find attached the calculation sheets for the fire protection systems at the proposed Elcon Recycling facility in Falls Township, Pennsylvania. The calculations are based on the preliminary architectural programming for the site, the International Fire Code, and NFPA 13, 20, and 22.

It is planned to install two fire pumps, each rated at 2,000 gpm. One pump will be electric and the other will be powered by a diesel engine. In addition, a 500,000-gallon storage tank will be installed to store firewater, which is approximately 67% larger than what the calculations specify. Please do not hesitate to contact me if you have any questions.

Very truly yours,

*James R. Rutenbar* /e/

James R. Rutenbar, P.E., LEED AP  
Director,  
Engineering and Construction

Attachments

cc: Z. Elgat, IES  
M. Fitzpatrick, IES  
A. Soni, IES

# Sprinkler Design Criteria Schedule & Calcs

OCCUPANCY/ SPACE TYPES	OCCUPANCY/ COMMODITY CLASSIFICATION	SYSTEM TYPE	MAX AREA/ SPRINKLER (SQ FT)	CEILING DESIGN DENSITY (GPM/SQ FT)	CEILING DESIGN AREA (SQ FT)	# OF DESIGN SPRINKLERS AT CEILING	MINIMUM OPERATING PRESSURE - CEILING SPRINKLERS (PSIG)	HOSE STREAM ALLOWANCE (GPM)	TOTAL ESTIMATED FLOW (GPM)	CODE REFERENCE
Office Building	LIGHT HAZARD	WET PIPE	225	0.10	1500	N/A	7	100	280	NFPA 13 11.2.3.3.1
Maintenance Building	ORDINARY HAZARD GR II	WET PIPE	130	0.20	1500	N/A	7	250	610	NFPA 13 11.2.3.3.1
Utilities Building	ORDINARY HAZARD GR II	WET PIPE	130	0.20	1500	N/A	7	250	610	NFPA 13 11.2.3.3.1
Production Plant	EXTRA HAZARD GR 2	WET PIPE	300	0.40	2500	N/A	7	500	1700	NFPA 13 11.2.3.3.1
Production Warehouse	SINGLE/DOUBLE ROW OPEN FRAME RACK STG OF CLASS I-IV COMMODITIES TO HT OF 25 FT W/MAX CLG HT OF 35 FT	WET PIPE	100	N/A	N/A	12 - K-25.2 PENDENT SPKRS, 4 ON EACH OF 3 REMOTE B-LINES	20	500	2125	NFPA 13, TABLE 16.2.3.1
Electrical Room	EXTRA HAZARD GR 2, FM GLOBAL HC-3	WET PIPE	100	0.15	1500	N/A	7	250	520	NFPA 13 11.2.3.3.1
Lab and Break Room	ORDINARY HAZARD GR II	WET PIPE	130	0.20	1500	N/A	7	250	610	NFPA 13 11.2.3.3.1

Fire pump is rated at 2000 gpm. Per NFPA 20, the pump must operate at 150% of its rated flow = 3000 gpm. NFPA 20 requires a 2000 gpm rated fire pump to have a min. 10 inch suction and 10 inch discharge per Table 5.25(b).

The water storage tank is sized to accommodate the largest square foot area of all combined floors in the Production Plant for a Type II Construction in accordance with IFC 2015 Appendix B.

In accordance with the highlighted items in Tables B105.1(2) and B105.2 below, = .25 x 4500 gpm x 240 minutes = 270,000 gallons rounded to 300,000 gallons





**TABLE B105.2  
REQUIRED FIRE-FLOW FOR BUILDINGS OTHER THAN ONE- AND  
TWO-FAMILY DWELLINGS, GROUP R-3 AND R-4 BUILDINGS AND TOWNHOUSES**

AUTOMATIC SPRINKLER SYSTEM (Design Standard)	MINIMUM FIRE-FLOW (gallons per minute)	FLOW DURATION (hours)
No automatic sprinkler system	Value in Table B105.1(C)	Duration in Table B105.1(C)
Section 903.3.1.1 of the <i>International Fire Code</i>	25% of the value in Table B105.1(C)	Duration in Table B105.1(C) at the reduced flow rate
Section 903.3.1.2 of the <i>International Fire Code</i>	25% of the value in Table B105.1(C)	Duration in Table B105.1(C) at the reduced flow rate

For SI, 1 gallon per minute = 3.785 L/min.

- The reduced fire-flow shall be not less than 1,000 gallons per minute.
- The reduced fire-flow shall be not less than 1,500 gallons per minute.

Calc for flow of max 3000 gpm through 10 inch DIP, CL 52 below.

6/12/2019


Flow Calculator

## Flow Calculator

Choose any diameter and instantly obtain the flow rate (gpm) and head-loss (ft/1,000 ft) results for the design-default velocity of 5.0 fps. Override any of the result values to easily recalculate all other parameters at the touch of a single button. (Employs the standardized Hazen-Williams hydraulic equations and principals)

Diameter (in)	Class
10	52
Velocity (ft/sec)	Flow Rate (gal/min)
11.61	3000
Head Loss (ft/1000 ft of Pipe)	Hazen-Williams C factor
36.02	140


**Structural Calculations  
Containments  
Elcon Recycling Facility  
Falls Township, PA**



*Albert P. Popoli*  
4/17/2019

Prepared By:


IES Engineers  
1720 Walton Road  
Blue Bell, PA 19422  
IES Project No. EG151065



REV 1

*Albert P. Popoli*  
1/24/2019

Albert P. Popoli  
PA P.E. No. 35446




1/2/2017

*Albert P. Popoli*

**Table of Contents**

	<b>Page No.</b>
Scope	A2
Technical References	A2
Project References	A2
Design Criteria	A2
Seismic Criteria	A3 – A7
Geotechnical Recommendations	A8
Project Approach	A8
Summary	A8
Wall Design – General	W1 – W2
12 inch Wall	W3 – W5
8 inch Wall	W6 – W7
Tank Containment Mat Design	
Area 5 Loading	M1
Area 6 Loading	M2
Area 11 Loading	M2
Area 7 Loading	M3
Saddle Supported Tank Loading	M4
Seismic – Areas 5, 6, 7, 11	M5 – M6
Wind on Containments 5, 6, 7, 11	M7
Standard Mat Design	M8
Conclusions	M9
Truck Unloading Slab (Area 9)	T1 – T3
Process Building Mat	P1 – P3
Warehouse Foundation and Slab	S1 – S3
Perimeter/Security Wall	R1 – R27
	RIA
	R1 – R19



REV 1 1/24/2019  
7/29/2016

### **Geotechnical Recommendations**

The Report offered two options for support: Ground Improvement or 30 ton timber piles. An economic analysis by Contractors will determine which system is used. All buildings and containments will be supported by the selected system.

The allowable soil bearing for ground improvement is 6000 pounds per square foot. The equivalent average soil bearing for piles spaced at three feet on center is  $30(2000)/(3 \times 3) = 6667$  psf. These equivalent bearing pressures are within eleven percent, a design based on soil bearing will be conservative provided the mat is thick enough to resist punching shear for a fully loaded pile.

Groundwater was measured at (-15 feet) below grade (El. 3.0). The 100 year flood (El. 16.8) level is below the bottom of the lowest containment mat.

### **Project Approach**

Design walls and mats for containment. Wall heights were established by the Containment Calculations. Determine the minimum required concrete thickness and reinforcing.

Wall designs will be based on a fluid level at the top of the wall, regardless of the calculated spill depth. Mat designs will be based on either the spill load or the typical operating condition. Differential settlement within the mat shall also be considered.

Wind or seismic loads will be applied for the tank farm containments. Given the large width of the foundations, overturning from lateral loads is expected to be minimal.

### **Summary**

Minimum wall and mat thicknesses and reinforcing have been established for the containments and the building foundations that also serve as containments. Other factors (frost protection, pipe racks, final vendor loads) may require an increase the wall/mat thickness or reinforcing.

Seismic and wind were considered for tank farms, the effects had no impact on the final design. Seismic and wind forces for the main process building may require an increase in mat thickness or reinforcing beyond that required by the containment criteria.

# USGS Design Maps Summary Report


## User-Specified Input

**Building Code Reference Document** 2006/2009 International Building Code  
(which utilizes USGS hazard data available in 2002)

**Site Coordinates** 40.17°N, 74.76°W

**Site Soil Classification** Site Class D - "Stiff Soil"


**Occupancy Category** I/II/III




## USGS-Provided Output

$S_s = 0.286 \text{ g}$	$S_{MS} = 0.449 \text{ g}$	$S_{DS} = 0.299 \text{ g}$
$S_1 = 0.062 \text{ g}$	$S_{M1} = 0.148 \text{ g}$	$S_{D1} = 0.099 \text{ g}$

**MCE Response Spectrum**



**Design Response Spectrum**



Although this information is a product of the U.S. Geological Survey, we provide no warranty, expressed or implied, as to the accuracy of the data contained therein. This tool is not a substitute for technical subject-matter knowledge.


**Design Maps Detailed Report**

2006/2009 International Building Code (40.17°N, 74.76°W)

Site Class D – “Stiff Soil”, Occupancy Category I/II/III

**Section 1613.5.1 – Mapped acceleration parameters**

Note: Maps in the 2006 and 2009 International Building Code are provided for Site Class

B. Adjustments for other Site Classes are made, as needed, in Section 1613.5.3.

From **Figure 1613.5(1)** <sup>[1]</sup>

$S_5 = 0.286 \text{ g}$

From **Figure 1613.5(2)** <sup>[2]</sup>

$S_1 = 0.062 \text{ g}$

**Section 1613.5.2 – Site class definitions**

<b>SITE CLASS</b>	<b>SOIL PROFILE NAME</b>	<b>Soil shear wave velocity, <math>\bar{v}_s</math>, (ft/s)</b>	<b>Standard penetration resistance, <math>\bar{N}</math></b>	<b>Soil undrained shear strength, <math>\bar{s}_u</math>, (psf)</b>
A	Hard rock	$\bar{v}_s > 5,000$	N/A	N/A
B	Rock	$2,500 < \bar{v}_s \leq 5,000$	N/A	N/A
C	Very dense soil and soft rock	$1,200 < \bar{v}_s \leq 2,500$	$\bar{N} > 50$	$>2,000$ psf
D	Stiff soil profile	$600 \leq \bar{v}_s < 1,200$	$15 \leq \bar{N} \leq 50$	1,000 to 2,000 psf
E	Stiff soil profile	$\bar{v}_s < 600$	$\bar{N} < 15$	$<1,000$ psf
E	—	Any profile with more than 10 ft of soil having the characteristics: <ol style="list-style-type: none"> <li>1. Plasticity index <math>PI &gt; 20</math>,</li> <li>2. Moisture content <math>w \geq 40\%</math>, and</li> <li>3. Undrained shear strength <math>\bar{s}_u &lt; 500</math> psf</li> </ol>		
F	—	Any profile containing soils having one or more of the following characteristics: <ol style="list-style-type: none"> <li>1. Soils vulnerable to potential failure or collapse under seismic loading such as liquefiable soils, quick and highly sensitive clays, collapsible weakly cemented soils.</li> <li>2. Peats and/or highly organic clays (<math>H &gt; 10</math> feet of peat and/or highly organic clay where <math>H</math> = thickness of soil)</li> <li>3. Very high plasticity clays (<math>H &gt; 25</math> feet with plasticity index <math>PI &gt; 75</math>)</li> <li>4. Very thick soft/medium stiff clays (<math>H &gt; 120</math> feet)</li> </ol>		

For SI: 1ft/s = 0.3048 m/s 1lb/ft<sup>2</sup> = 0.0479 kN/m<sup>2</sup>

### Section 1613.5.3 — Site coefficients and adjusted maximum considered earthquake spectral response acceleration parameters

TABLE 1613.5.3(1)  
VALUES OF SITE COEFFICIENT  $F_a$

Site Class	Mapped Spectral Response Acceleration at Short Period				
	$S_s \leq 0.25$	$S_s = 0.50$	$S_s = 0.75$	$S_s = 1.00$	$S_s \geq 1.25$
A	0.8	0.8	0.8	0.8	0.8
B	1.0	1.0	1.0	1.0	1.0
C	1.2	1.2	1.1	1.0	1.0
D	1.6	1.4	1.2	1.1	1.0
E	2.5	1.7	1.2	0.9	0.9
F	See Section 11.4.7 of ASCE 7				

Note: Use straight-line interpolation for intermediate values of  $S_s$

For Site Class = D and  $S_s = 0.286$  g,  $F_a = 1.571$

TABLE 1613.5.3(2)  
VALUES OF SITE COEFFICIENT  $F_v$

Site Class	Mapped Spectral Response Acceleration at 1-s Period				
	$S_1 \leq 0.10$	$S_1 = 0.20$	$S_1 = 0.30$	$S_1 = 0.40$	$S_1 \geq 0.50$
A	0.8	0.8	0.8	0.8	0.8
B	1.0	1.0	1.0	1.0	1.0
C	1.7	1.6	1.5	1.4	1.3
D	2.4	2.0	1.8	1.6	1.5
E	3.5	3.2	2.8	2.4	2.4
F	See Section 11.4.7 of ASCE 7				

Note: Use straight-line interpolation for intermediate values of  $S_1$

For Site Class = D and  $S_1 = 0.062$  g,  $F_v = 2.400$

AG

In the equations below, the equation number corresponding to the 2006 edition is listed first, and that corresponding to the 2009 edition is listed second.

---

Equation (16-37; 16-36):  $S_{M5} = F_a S_5 = 1.571 \times 0.286 = 0.449 \text{ g}$

---

Equation (16-38; 16-37):  $S_{M1} = F_v S_1 = 2.400 \times 0.062 = 0.148 \text{ g}$

---

Section 1613.5.4 — Design spectral response acceleration parameters

---

Equation (16-39; 16-38):  $S_{D5} = \frac{2}{3} S_{M5} = \frac{2}{3} \times 0.449 = 0.299 \text{ g}$  USE 0.30g

---

Equation (16-40; 16-39):  $S_{D1} = \frac{2}{3} S_{M1} = \frac{2}{3} \times 0.148 = 0.099 \text{ g}$  USE 0.10g

---



## Section 1613.5.6 — Determination of seismic design category

TABLE 1613.5.6(1)

SEISMIC DESIGN CATEGORY BASED ON SHORT-PERIOD RESPONSE ACCELERATION

VALUE OF $S_{DS}$	OCCUPANCY CATEGORY		
	I or II	III	IV
$S_{DS} < 0.167g$	A	A	A
$0.167g \leq S_{DS} < 0.33g$	B	B	C
$0.33g \leq S_{DS} < 0.50g$	C	C	D
$0.50g \leq S_{DS}$	D	D	D

For Occupancy Category = I and  $S_{DS} = 0.299g$ , Seismic Design Category = B

TABLE 1613.5.6(2)

SEISMIC DESIGN CATEGORY BASED ON 1-SECOND PERIOD RESPONSE ACCELERATION

VALUE OF $S_{D1}$	OCCUPANCY CATEGORY		
	I or II	III	IV
$S_{D1} < 0.067g$	A	A	A
$0.067g \leq S_{D1} < 0.133g$	B	B	C
$0.133g \leq S_{D1} < 0.20g$	C	C	D
$0.20g \leq S_{D1}$	D	D	D

For Occupancy Category = I and  $S_{D1} = 0.099g$ , Seismic Design Category = B

Note: When  $S_1$  is greater than or equal to 0.75g, the Seismic Design Category is E for buildings in Occupancy Categories I, II, and III, and F for those in Occupancy Category IV, irrespective of the above.

Seismic Design Category  $\equiv$  "the more severe design category in accordance with Table 1613.5.6(1) or 1613.5.6(2)" = B


Note: See Section 1613.5.6.1 for alternative approaches to calculating Seismic Design Category.

## References

1. Figure 1613.5(1): [http://earthquake.usgs.gov/hazards/designmaps/downloads/pdfs/IBC-2006-Figure1613\\_5\(01\).pdf](http://earthquake.usgs.gov/hazards/designmaps/downloads/pdfs/IBC-2006-Figure1613_5(01).pdf)
2. Figure 1613.5(2): [http://earthquake.usgs.gov/hazards/designmaps/downloads/pdfs/IBC-2006-Figure1613\\_5\(02\).pdf](http://earthquake.usgs.gov/hazards/designmaps/downloads/pdfs/IBC-2006-Figure1613_5(02).pdf)

(REV 1: GRADE CHANGES - SEE PG RIA)

PERIMETER / SECURITY WALL




REF GEOTECH REPORT FOR SOIL PROPERTIES:

$\gamma = 125 \text{ pcf}$

$K_a = 0.31 \quad K_p = 3.75$

$M = 0.35 @ \text{BASE}$

TYPICAL CROSS SECTION



DESIGN CONDITIONS

LC1: D+L (SURCHARGE), NORMAL GWT

LC2: D+L (SURCHARGE), 100 YEAR FLOOD

LC3: D+L+SEISMIC, NORMAL GWT  
(D+H+0.75(TE)+0.75L)

LC4: D+L+WIND, NORMAL GWT  
D+H+.75L+0.75W

WORST CASE -  
SOIL SURCHARGE  
LOADING  
(TYPE 1 RETAINING WALL)

CONSIDER H2O AS 250 pcf  
@ SURFACE BEHIND WALL  
(NEGLECT ROAD OFFSET)


RETAINING WALL CHANGES - REVISION 1

LAYOUT AND REVIEW COMMENTS CREATED GRADING CHANGES (GIUMORE & ASSOCIATES, "GRADING AND DRAINAGE PLAN" DATED 12/10/18). THE "TYPE 1" RETAINING WALL DESIGN WAS REVIEWED AND CHANGED TO ACCOMMODATE A ONE FOOT INCREASE IN RETAINED HEIGHT. REVISED CALCULATION PAGES FOLLOW.

NOTE: ORIGINAL CALCS USED INCORRECT (TOO HIGH) 100 YEAR FLOOD FOR LOAD COMBINATION 2. CALCS REWORKED USING 500 YEAR FLOOD


NO CHANGES REQUIRED FOR SHORTER (TYPE 2) WALL. GROUND GRADES ON EACH SIDE LEVEL, AND THERE AREN'T ANY TRUCK WADINGS. DESIGN LEFT AS-IS.

REVISION 2 CHANGE



PER GIUMORE GRADING DWG 4/15/2019, MAX GRADE BEHIND WALL RAISED 1'0" BUT LOW SIDE ALSO RAISED 1'0". NO CHANGE TO DESIGN, STILL BASED ON 6'6" Δ HEIGHT

H<sub>2</sub>O LOADING : TYPICALLY CONSIDERED AS 2 FT OF SOIL (25 psf)




PRESCRIBED PRESSURE  
 $0.31(125) = 38.75$  USE  
 39 psf.

ANALYSIS PROGRAM USES ONE VALUE OF  $K_a$ .

MODIFY H<sub>2</sub>O LOAD IN PROGRAM TO GET SAME LOAD REQ'D BY GEOTECH ( $K_a = 0.5$  FOR SURCHARGE)

$W(0.31) = 125 \text{ psf}$      $W = 403$  Say 400 psf.  
 $400(0.31) = 124 \text{ psf}$  OK.

WALL STABILITY ANALYSIS USING CSC/TEDDS SOFTWARE. CALCS FOLLOW

 <b>Tedds</b> <b>IES Engineers</b> Blue Bell, PA 19422	<b>Project</b> Elcon Recycling			<b>Job Ref.</b> R3	
	<b>Section</b> Perimeter Wall - Max Height + surcharge, normal GWT			<b>Sheet no./rev.</b> 1	
	<b>Calc. by</b> A. Popoli	<b>Date</b> 1/24/2019	<b>Chkd by</b>	<b>Date</b>	<b>App'd by</b>

**RETAINING WALL ANALYSIS**

LC1

In accordance with IBC 2009

Tedds calculation version 2.4.06

**Retaining wall details**

Stem type	Cantilever		
Stem height	$h_{stem} = 9$ ft		
Stem thickness	$t_{stem} = 12$ in		
Angle to rear face of stem	$\alpha = 90$ deg		
Stem density	$\gamma_{stem} = 150$ pcf		
Toe length	$l_{toe} = 1$ ft		
Heel length	$l_{heel} = 4$ ft		
Base thickness	$t_{base} = 12$ in		
Key depth	$d_{key} = 1$ ft	Key thickness	$t_{key} = 12$ in
Key position	$p_{key} = 1$ ft		
Base density	$\gamma_{base} = 150$ pcf		
Height of retained soil	$h_{ret} = 6.5$ ft	Angle of soil surface	$\beta = 0$ deg
Depth of cover	$d_{cover} = 2$ ft		

**Retained soil properties**


Soil type	Medium dense well graded sand		
Moist density	$\gamma_{mr} = 125$ pcf		
Saturated density	$\gamma_{sr} = 145$ pcf		
Effective angle of internal resistance		$\phi_r = 32$ deg	
Effective wall friction angle	$\delta_r = 16$ deg		


**Base soil properties**

Soil type	Medium dense well graded sand		
Moist density	$\gamma_{mb} = 125$ pcf		
Cohesion	$c_b = 0$ psf		
Effective angle of internal resistance		$\phi_b = 32$ deg	
Effective wall friction angle	$\delta_b = 15$ deg		
Effective base friction angle	$\delta_{bb} = 30$ deg		
Allowable bearing pressure	$P_{bearing} = 3500$ psf		

**Loading details**

Live surcharge load	Surcharge <sub>L</sub> = 400 psf
---------------------	----------------------------------

 Tedds IES Engineers  Blue Bell, PA 19422	Project <b>Elcon Recycling</b>			Job Ref <b>R4</b>	
	Section <b>Perimeter Wall - Max Height + surcharge, normal GWT</b>			Sheet no./rev <b>2</b>	
	Calc. by <b>A. Popoli</b>	Date <b>1/24/2019</b>	Chk'd by	Date	App'd by



**Calculate retaining wall geometry**

Base length	$l_{base} = 6 \text{ ft}$
Base height	$h_{base} = 2 \text{ ft}$
Moist soil height	$h_{moist} = 8.5 \text{ ft}$
Length of surcharge load	$l_{sur} = 4 \text{ ft}$
Vertical distance	$x_{sur_v} = 4 \text{ ft}$
Effective height of wall	$h_{eff} = 10.5 \text{ ft}$
Horizontal distance	$x_{sur_h} = 4.25 \text{ ft}$
Horizontal distance above key	$x_{sur_h_a} = 4.75 \text{ ft}$
Area of wall stem	$A_{stem} = 9 \text{ ft}^2$
Area of wall base	$A_{base} = 7 \text{ ft}^2$
Area of moist soil	$A_{moist} = 34 \text{ ft}^2$

Vertical distance	$x_{stem} = 1.5 \text{ ft}$
Vertical distance	$x_{base} = 2.786 \text{ ft}$
Vertical distance	$x_{moist_v} = 4 \text{ ft}$
Horizontal distance	$x_{moist_h} = 2.5 \text{ ft}$
Horizontal distance above key	$x_{moist_h_a} = 3.167 \text{ ft}$
Vertical distance	$x_{pass_v} = 0.5 \text{ ft}$
Horizontal distance	$x_{pass_h} = 0.333 \text{ ft}$
Vertical distance	$x_{exc_v} = 0.5 \text{ ft}$
Horizontal distance	$x_{exc_h} = 0.333 \text{ ft}$

Area of base soil	$A_{pass} = 2 \text{ ft}^2$
Area of excavated base soil	$A_{exc} = 2 \text{ ft}^2$

Using Rankine theory  
 Active pressure coefficient  $K_A = 0.307$  ✓

Passive pressure coefficient  $K_P = 3.255$  ✓

Project Elcon Recycling			Job Ref. R5		
Section Perimeter Wall - Max Height + surcharge, normal GWT			Sheet no./rev. 3		
Calc. by A. Popoli	Date 1/24/2019	Chk'd by	Date	App'd by	Date


From IBC 2009 cl.1807.2.3 Safety factor

**CHECK SLIDING COMPONENTS**

Load combination 1

$1.0 \times \text{Dead} + 1.0 \times \text{Live} + 1.0 \times \text{Lateral earth}$

Sliding check

$4(125)(375) = 1625$   4'

Vertical forces on wall

Total

$F_{\text{total}_v} = F_{\text{stem}} + F_{\text{base}} + F_{\text{moist}_v} + F_{\text{exc}_v} = 6900 \text{ plf} \times 0.35 = 2415\#$  **BASE FRICTION**

Horizontal forces on wall

Total

$F_{\text{total}_h} = F_{\text{moist}_h} + F_{\text{sur}_h} = 3408 \text{ plf}$   
 $P_p = 1625(4)/2 = 3250$  **PASSIVE PRESS**  
 $\rightarrow 5665\#$  **OK**

Check stability against sliding

Resistance to sliding

$F_{\text{rest}} = 5584 \text{ plf}$

Factor of safety

$FoS_{sl} = 1.639 > 1.5$

**PASS - Factor of safety against sliding is adequate**

Overturning check

Vertical forces on wall

Total

$F_{\text{total}_v} = F_{\text{stem}} + F_{\text{base}} + F_{\text{moist}_v} + F_{\text{exc}_v} = 6900 \text{ plf}$

Horizontal forces on wall

Total

$F_{\text{total}_h} = F_{\text{moist}_h} + F_{\text{exc}_h} + F_{\text{sur}_h} = 1301 \text{ plf}$

Overturning moments on wall

Total

$M_{\text{total}_OT} = M_{\text{moist}_OT} + M_{\text{sur}_OT} = 11034 \text{ lb}_\cdot\text{ft/ft}$

Restoring moments on wall

Total

$M_{\text{total}_R} = M_{\text{stem}_R} + M_{\text{base}_R} + M_{\text{moist}_R} + M_{\text{exc}_R} = 22608 \text{ lb}_\cdot\text{ft/ft}$

Check stability against overturning

Factor of safety

$FoS_{ot} = 2.049 > 1.5$

**PASS - Factor of safety against overturning is adequate**

Bearing pressure check

Vertical forces on wall

Total

$F_{\text{total}_v} = F_{\text{stem}} + F_{\text{base}} + F_{\text{moist}_v} + F_{\text{pass}_v} + F_{\text{sur}_v} = 8500 \text{ plf}$

Horizontal forces on wall

Total

$F_{\text{total}_h} = \max(F_{\text{moist}_h} + F_{\text{pass}_h} + F_{\text{sur}_h} - F_{\text{total}_v} \times \tan(\delta_{bb}), 0 \text{ plf}) = 0 \text{ plf}$

Moments on wall

Total

$M_{\text{total}} = M_{\text{stem}} + M_{\text{base}} + M_{\text{moist}} + M_{\text{pass}} + M_{\text{sur}} = 17441 \text{ lb}_\cdot\text{ft/ft}$

Check bearing pressure

Bearing pressure at toe

$q_{\text{toe}} = 2760 \text{ psf}$

Bearing pressure at heel

$q_{\text{heel}} = 73 \text{ psf}$

Factor of safety

$FoS_{bp} = 1.268$

**PASS - Allowable bearing pressure exceeds maximum applied bearing pressure**

**RETAINING WALL DESIGN**

In accordance with ACI 318-08

Tedds calculation version 2.4.06

Concrete details

Compressive strength

$f_c = 4000 \text{ psi}$

Concrete type

Normal weight


Reinforcement details

Yield strength

$f_y = 60000 \text{ psi}$

Modulus of elasticity

$E_s = 29000000 \text{ psi}$

 <b>Tedds</b> <b>IES Engineers</b> Blue Bell, PA 19422	Project Elcon Recycling			Job Ref. RG	
	Section Perimeter Wall - Max Height + surcharge, normal GWT			Sheet no./rev. 4	
	Calc. by A. Popoli	Date 1/24/2019	Chk'd by	Date	App'd by

**Cover to reinforcement**

Front face of stem	$c_{sf} = 2$ in	Rear face of stem	$c_{sr} = 3$ in
Top face of base	$c_{bt} = 2$ in	Bottom face of base	$c_{bb} = 3$ in

**From IBC 2009 cl.1605.2.1 Basic load combinations**

Load combination no.1	1.4 × Dead
Load combination no.2	1.2 × Dead + 1.6 × Live + 1.6 × Lateral earth
Load combination no.3	1.2 × Dead + 1.0 × Earthquake + 1.0 × Live
Load combination no.4	0.9 × Dead + 1.0 × Earthquake + 1.6 × Lateral earth

**Check stem design at base of stem**

Depth of section  $h = 12$  in

**Rectangular section in flexure - Chapter 10**

Factored bending moment	$M = 13394$ lb <sub>f</sub> /ft	Tens.reinforcement provided	$A_{sr,prov} = 0.442$ in <sup>2</sup> /ft
Tens.reinforcement provided	No.6 bars @ 12" c/c		
Max.reinforcement spacing	$s_{max} = 18$ in		

**PASS - Reinforcement is adequately spaced**

Nominal flexural strength	$M_n = 18334$ lb <sub>f</sub> /ft	Strength reduction factor	$\phi_r = 0.9$
Design flexural strength	$\phi M_n = 16501$ lb <sub>f</sub> /ft	$M / \phi M_n = 0.812$	

**PASS - Design flexural strength exceeds factored bending moment**

Reinforcement by analysis	$A_{sr,des} = 0.356$ in <sup>2</sup> /ft	Min.tension reinforcement	$A_{sr,min} = 0.345$ in <sup>2</sup> /ft
---------------------------	--	---------------------------	--

**PASS - Area of reinforcement provided is greater than minimum area of reinforcement required**

**Rectangular section in shear - Chapter 11**

Factored shear force	$V = 3891$ lb/ft	Strength reduction factor	$\phi_s = 0.75$
Nominal conc.shear strength	$V_c = 13092$ lb/ft	$V / \phi V_c = 0.396$	
Design conc.shear strength	$\phi V_c = 9819$ lb/ft		

**PASS - No shear reinforcement is required**

**Horizontal reinforcement parallel to face of stem**

Min.area of reinforcement	$A_{sx,req} = 0.288$ in <sup>2</sup> /ft	Trans.reinforcement provided	$A_{sx,prov} = 0.589$ in <sup>2</sup> /ft
Trans.reinforcement provided	No.4 bars @ 8" c/c each face		

**PASS - Area of reinforcement provided is greater than area of reinforcement required**

**Check base design at toe**

Depth of section  $h = 12$  in

**Rectangular section in flexure - Chapter 10**

Factored bending moment	$M = 1684$ lb <sub>f</sub> /ft	Tens.reinforcement provided	$A_{bb,prov} = 0.295$ in <sup>2</sup> /ft
Tens.reinforcement provided	No.4 bars @ 8" c/c		
Max.reinforcement spacing	$s_{max} = 18$ in		

**PASS - Reinforcement is adequately spaced**


Nominal flexural strength	$M_n = 12567$ lb <sub>f</sub> /ft	Strength reduction factor	$\phi_r = 0.9$
Design flexural strength	$\phi M_n = 11310$ lb <sub>f</sub> /ft	$M / \phi M_n = 0.149$	

**PASS - Design flexural strength exceeds factored bending moment**

Reinforcement by analysis	$A_{bb,des} = 0.043$ in <sup>2</sup> /ft	Min.tension reinforcement	$A_{bb,min} = 0.259$ in <sup>2</sup> /ft
---------------------------	--	---------------------------	--

**PASS - Area of reinforcement provided is greater than minimum area of reinforcement required**



 Tedds' IES Engineers Blue Bell, PA 19422	Project Elcon Recycling		Job Ref. R7		
	Section Perimeter Wall - Max Height + surcharge, normal GWT		Sheet no./rev. 5		
	Calc. by A. Popoli	Date 1/24/2019	Chk'd by	Date	App'd by

**Rectangular section in shear - Chapter 11**

Factored shear force  $V = 3238$  lb/ft

Nominal conc. shear strength  $V_c = 13282$  lb/ft

Design conc. shear strength  $\phi V_c = 9961$  lb/ft

Strength reduction factor  $\phi_s = 0.75$

$V / \phi V_c = 0.325$

**PASS - No shear reinforcement is required**

**Rectangular section in flexure - Chapter 10**

*HEEL*

Factored bending moment  $M = 12189$  lb<sub>ft</sub>/ft

Tens. reinforcement provided No.4 bars @ 8" c/c

Max. reinforcement spacing  $s_{max} = 18$  in

Tens. reinforcement provided  $A_{b,prov} = 0.295$  in<sup>2</sup>/ft

**PASS - Reinforcement is adequately spaced**

Nominal flexural strength  $M_n = 14039$  lb<sub>ft</sub>/ft

Design flexural strength  $\phi M_n = 12635$  lb<sub>ft</sub>/ft

Strength reduction factor  $\phi_f = 0.9$

$M / \phi M_n = 0.965$

**PASS - Design flexural strength exceeds factored bending moment**

Reinforcement by analysis  $A_{b,des} = 0.284$  in<sup>2</sup>/ft

Min. tension reinforcement  $A_{b,min} = 0.259$  in<sup>2</sup>/ft

**PASS - Area of reinforcement provided is greater than minimum area of reinforcement required**

**Rectangular section in shear - Chapter 11**

Factored shear force  $V = 4198$  lb/ft

Nominal conc. shear strength  $V_c = 14799$  lb/ft

Design conc. shear strength  $\phi V_c = 11100$  lb/ft

Strength reduction factor  $\phi_s = 0.75$

$V / \phi V_c = 0.378$

**PASS - No shear reinforcement is required**

**Check key design**

Depth of section  $h = 12$  in

**Rectangular section in flexure - Chapter 10**

Factored bending moment  $M = 710$  lb<sub>ft</sub>/ft

Tens. reinforcement provided No.4 bars @ 8" c/c

Max. reinforcement spacing  $s_{max} = 18$  in

Tens reinforcement provided  $A_{k,prov} = 0.295$  in<sup>2</sup>/ft

**PASS - Reinforcement is adequately spaced**

Nominal flexural strength  $M_n = 12567$  lb<sub>ft</sub>/ft

Design flexural strength  $\phi M_n = 11310$  lb<sub>ft</sub>/ft

Strength reduction factor  $\phi_f = 0.9$

$M / \phi M_n = 0.063$

**PASS - Design flexural strength exceeds factored bending moment**

Reinforcement by analysis  $A_{k,des} = 0.018$  in<sup>2</sup>/ft

Min. tension reinforcement  $A_{k,min} = 0.259$  in<sup>2</sup>/ft

**PASS - Area of reinforcement provided is greater than minimum area of reinforcement required**

**Rectangular section in shear - Chapter 11**

Factored shear force  $V = 1331$  lb/ft

Nominal conc. shear strength  $V_c = 13282$  lb/ft

Design conc. shear strength  $\phi V_c = 9961$  lb/ft

Strength reduction factor  $\phi_s = 0.75$

$V / \phi V_c = 0.134$


**PASS - No shear reinforcement is required**


**Transverse reinforcement parallel to base**

Min. area of reinforcement  $A_{bx,req} = 0.259$  in<sup>2</sup>/ft

Trans. reinforcement provided No.4 bars @ 8" c/c each face Trans. reinforcement provided  $A_{bx,prov} = 0.589$  in<sup>2</sup>/ft

**PASS - Area of reinforcement provided is greater than area of reinforcement required**

 Tedds IES Engineers Blue Bell, PA 19422	Project Elcon Recycling			Job Ref. RB	
	Section Perimeter Wall - Max Height + surcharge, normal GWT			Sheet no./rev. 6	
	Calc. by A. Popoli	Date 1/24/2019	Chk'd by	Date	App'd by



 <b>Tedds</b> <b>IES Engineers</b> Blue Bell, PA 19422	Project <b>Elcon Recycling</b>			Job Ref. <b>RBA</b>	
	Section <b>Perimeter Wall - Max Height + surcharge, 500 Year Flood</b>			Sheet no./rev. <b>1</b>	
	Calc. by <b>A. Popoli</b>	Date <b>1/24/2019</b>	Chk'd by	Date	App'd by

**RETAINING WALL ANALYSIS**

**LC2 (FLOOD)**

In accordance with IBC 2009

Tedds calculation version 2.4.06

**Retaining wall details**

Stem type	Cantilever		
Stem height	$h_{stem} = 9$ ft		
Stem thickness	$t_{stem} = 12$ in		
Angle to rear face of stem	$\alpha = 90$ deg		
Stem density	$\gamma_{stem} = 150$ pcf		
Toe length	$l_{toe} = 1$ ft		
Heel length	$l_{heel} = 4$ ft		
Base thickness	$t_{base} = 12$ in		
Key depth	$d_{key} = 1$ ft	Key thickness	$t_{key} = 12$ in
Key position	$p_{key} = 1$ ft		
Base density	$\gamma_{base} = 150$ pcf		
Height of retained soil	$h_{ret} = 6.5$ ft	Angle of soil surface	$\beta = 0$ deg
Depth of cover	$d_{cover} = 2$ ft		
Height of water	$h_{water} = 4$ ft		
Water density	$\gamma_w = 62$ pcf		

**Retained soil properties**


Soil type	Medium dense well graded sand		
Moist density	$\gamma_{mr} = 125$ pcf		
Saturated density	$\gamma_{sr} = 145$ pcf		
Effective angle of internal resistance		$\phi_r = 32$ deg	
Effective wall friction angle	$\delta_r = 16$ deg		

**Base soil properties**

Soil type	Medium dense well graded sand		
Moist density	$\gamma_{mb} = 125$ pcf		
Cohesion	$c_b = 0$ psf		
Effective angle of internal resistance		$\phi_b = 32$ deg	
Effective wall friction angle	$\delta_b = 15$ deg		
Effective base friction angle	$\delta_{bb} = 30$ deg		
Allowable bearing pressure	$P_{bearing} = 3500$ psf		

**Loading details**

Live surcharge load	Surcharge <sub>L</sub> = 400 psf
---------------------	----------------------------------




CONSERVATIVE - PROGRAM CAN'T PUT WATER @ FRONT OF WALL, ANALYSIS REPRESENTS POST-FLOOD CONDITION W/ WATER TRAPPED BEHIND WALL - VERY CONSERVATIVE.

**Calculate retaining wall geometry**

Base length	$l_{base} = 6 \text{ ft}$
Base height	$h_{base} = 2 \text{ ft}$
Saturated soil height	$h_{sat} = 6 \text{ ft}$
Moist soil height	$h_{moist} = 2.5 \text{ ft}$
Length of surcharge load	$l_{sur} = 4 \text{ ft}$
Vertical distance	$x_{sur\_v} = 4 \text{ ft}$
Effective height of wall	$h_{eff} = 10.5 \text{ ft}$
Horizontal distance	$x_{sur\_h} = 4.25 \text{ ft}$
Horizontal distance above key	$x_{sur\_h\_a} = 4.75 \text{ ft}$
Area of wall stem	$A_{stem} = 9 \text{ ft}^2$
Area of wall base	$A_{base} = 7 \text{ ft}^2$
Area of saturated soil	$A_{sat} = 24 \text{ ft}^2$
Area of water	$A_{water} = 24 \text{ ft}^2$
Area of moist soil	$A_{moist} = 10 \text{ ft}^2$

Vertical distance	$x_{stem} = 1.5 \text{ ft}$
Vertical distance	$x_{base} = 2.786 \text{ ft}$
Vertical distance	$x_{sat\_v} = 4 \text{ ft}$
Horizontal distance	$x_{sat\_h} = 1.667 \text{ ft}$
Horizontal distance above key	$x_{sat\_h\_a} = 2.333 \text{ ft}$
Vertical distance	$x_{water\_v} = 4 \text{ ft}$
Horizontal distance	$x_{water\_h} = 1.667 \text{ ft}$
Horizontal distance above key	$x_{water\_h\_a} = 2.333 \text{ ft}$
Vertical distance	$x_{moist\_v} = 4 \text{ ft}$
Horizontal distance	$x_{moist\_h} = 3.653 \text{ ft}$
Horizontal distance above key	$x_{moist\_h\_a} = 4.157 \text{ ft}$

 <p>Tedds IES Engineers Blue Bell, PA 19422</p>	Project Elcon Recycling			Job Ref. R10	
	Section Perimeter Wall - Max Height + surcharge, 500 Year Flood			Sheet no./rev. 3	
	Calc. by A. Popoli	Date 1/24/2019	Chk'd by	Date	App'd by

Area of base soil  $A_{pass} = 2 \text{ ft}^2$       Vertical distance  $x_{pass_v} = 0.5 \text{ ft}$   
Horizontal distance  $x_{pass_h} = 0.333 \text{ ft}$

Area of excavated base soil  $A_{exc} = 2 \text{ ft}^2$       Vertical distance  $x_{exc_v} = 0.5 \text{ ft}$   
Horizontal distance  $x_{exc_h} = 0.333 \text{ ft}$

**Using Rankine theory**

Active pressure coefficient  $K_A = 0.307$       Passive pressure coefficient  $K_P = 3.255$

**From IBC 2009 cl.1807.2.3 Safety factor**

Load combination 1  $1.0 \times \text{Dead} + 1.0 \times \text{Live} + 1.0 \times \text{Lateral earth}$

**Sliding check**

**Vertical forces on wall**

Total  $F_{total_v} = F_{stem} + F_{base} + F_{sat_v} + F_{moist_v} + F_{exc_v} + F_{water_v} = 7380 \text{ plf}$

**Horizontal forces on wall**

Total  $F_{total_h} = F_{sat_h} + F_{moist_h} + F_{water_h} + F_{sur_h} = 4985 \text{ plf}$

**Check stability against sliding**

Resistance to sliding  $F_{rest} = 7515 \text{ plf}$       Factor of safety  $FoS_{sl} = 1.507 > 1.5$   
**PASS - Factor of safety against sliding is adequate**

**Overturning check**

**Vertical forces on wall**

Total  $F_{total_v} = F_{stem} + F_{base} + F_{sat_v} + F_{moist_v} + F_{exc_v} + F_{water_v} = 7380 \text{ plf}$

**Horizontal forces on wall**

Total  $F_{total_h} = F_{sat_h} + F_{moist_h} + F_{exc_h} + F_{water_h} + F_{sur_h} = 854 \text{ plf}$

**Overturning moments on wall**

Total  $M_{total_{OT}} = M_{sat_{OT}} + M_{moist_{OT}} + M_{water_{OT}} + M_{sur_{OT}} = 13853 \text{ lb\_ft/ft}$

**Restoring moments on wall**

Total  $M_{total_R} = M_{stem_R} + M_{base_R} + M_{sat_R} + M_{moist_R} + M_{exc_R} + M_{water_R} = 25080 \text{ lb\_ft/ft}$

**Check stability against overturning**

Factor of safety  $FoS_{ot} = 1.81 > 1.5$   
**PASS - Factor of safety against overturning is adequate**

**Bearing pressure check**

**Vertical forces on wall**

Total  $F_{total_v} = F_{stem} + F_{base} + F_{sat_v} + F_{moist_v} + F_{pass_v} + F_{water_v} + F_{sur_v} = 8980 \text{ plf}$

**Horizontal forces on wall**

Total  $F_{total_h} = \max(F_{sat_h} + F_{moist_h} + F_{pass_h} + F_{water_h} + F_{sur_h} - F_{total_v} \times \tan(\delta_{bb}), 0 \text{ plf}) = 0 \text{ plf}$


**Moments on wall**

Total  $M_{total} = M_{stem} + M_{base} + M_{sat} + M_{moist} + M_{pass} + M_{water} + M_{sur} = 16542 \text{ lb\_ft/ft}$

**Check bearing pressure**

Bearing pressure at toe  $q_{toe} = 3250 \text{ psf}$       Bearing pressure at heel  $q_{heel} = 0 \text{ psf}$   
Factor of safety  $FoS_{bp} = 1.077$

**PASS - Allowable bearing pressure exceeds maximum applied bearing pressure**

 <b>Tedds</b> <b>IES Engineers</b> Blue Bell, PA 19422	Project Elcon Recycling			Job Ref. <b>R11</b>	
	Section Perimeter Wall - Max Height + surcharge, 500 Year Flood			Sheet no./rev. 4	
	Calc. by A. Popoli	Date 1/24/2019	Chk'd by	Date	App'd by

### RETAINING WALL DESIGN

In accordance with ACI 318-08

Tedds calculation version 2.4.06

#### Concrete details

Compressive strength  $f_c = 4000$  psi      Concrete type      Normal weight

#### Reinforcement details

Yield strength  $f_y = 60000$  psi      Modulus of elasticity       $E_s = 29000000$  psi

#### Cover to reinforcement

Front face of stem       $C_{sf} = 2$  in      Rear face of stem       $C_{sr} = 3$  in  
 Top face of base       $C_{ot} = 2$  in      Bottom face of base       $C_{ob} = 3$  in

#### From IBC 2009 cl.1605.2.1 Basic load combinations

Load combination no.1       $1.4 \times \text{Dead}$   
 Load combination no.2       $1.2 \times \text{Dead} + 1.6 \times \text{Live} + 1.6 \times \text{Lateral earth}$   
 Load combination no.3       $1.2 \times \text{Dead} + 1.0 \times \text{Earthquake} + 1.0 \times \text{Live}$   
 Load combination no.4       $0.9 \times \text{Dead} + 1.0 \times \text{Earthquake} + 1.6 \times \text{Lateral earth}$

#### Check stem design at base of stem

Depth of section       $h = 12$  in

#### Rectangular section in flexure - Chapter 10

Factored bending moment       $M = 14609$  lb<sub>ft</sub>/ft  
 Tens.reinforcement provided      No.6 bars @ 12" c/c      Tens.reinforcement provided       $A_{sr,prov} = 0.442$  in<sup>2</sup>/ft  
 Max.reinforcement spacing       $S_{max} = 18$  in

*PASS - Reinforcement is adequately spaced*

Nominal flexural strength       $M_n = 18334$  lb<sub>ft</sub>/ft      Strength reduction factor       $\phi_f = 0.9$   
 Design flexural strength       $\phi M_n = 16501$  lb<sub>ft</sub>/ft       $M / \phi M_n = 0.885$

*PASS - Design flexural strength exceeds factored bending moment*

Reinforcement by analysis       $A_{sr,des} = 0.389$  in<sup>2</sup>/ft      Min.tension reinforcement       $A_{sr,min} = 0.345$  in<sup>2</sup>/ft

*PASS - Area of reinforcement provided is greater than minimum area of reinforcement required*

#### Rectangular section in shear - Chapter 11

Factored shear force       $V = 4599$  lb/ft  
 Nominal conc.shear strength       $V_c = 13092$  lb/ft      Strength reduction factor       $\phi_s = 0.75$   
 Design conc.shear strength       $\phi V_c = 9819$  lb/ft       $V / \phi V_c = 0.468$

*PASS - No shear reinforcement is required*

#### Horizontal reinforcement parallel to face of stem

Min.area of reinforcement       $A_{sr,req} = 0.288$  in<sup>2</sup>/ft  
 Trans.reinforcement provided      No.4 bars @ 8" c/c each face      Trans.reinforcement provided       $A_{sr,prov} = 0.589$  in<sup>2</sup>/ft

*PASS - Area of reinforcement provided is greater than area of reinforcement required*

#### Check base design at toe

Depth of section       $h = 12$  in

#### Rectangular section in flexure - Chapter 10

Factored bending moment       $M = 2142$  lb<sub>ft</sub>/ft  
 Tens.reinforcement provided      **No.4 bars @ 8" c/c**      *# 5 @ 12" (0.31 in<sup>2</sup>/ft)*      Tens.reinforcement provided       $A_{sr,prov} = 0.295$  in<sup>2</sup>/ft  
 Max.reinforcement spacing       $S_{max} = 18$  in

Project Elcon Recycling			Job Ref. R12		
Section Perimeter Wall - Max Height + surcharge, 500 Year Flood			Sheet no./rev. 5		
Calc. by A. Popoli	Date 1/24/2019	Chk'd by	Date	App'd by	Date

**PASS - Reinforcement is adequately spaced**

Nominal flexural strength  $M_n = 12567 \text{ lb\_ft/ft}$  Strength reduction factor  $\phi_f = 0.9$   
 Design flexural strength  $\phi M_n = 11310 \text{ lb\_ft/ft}$   $M / \phi M_n = 0.189$

**PASS - Design flexural strength exceeds factored bending moment**

Reinforcement by analysis  $A_{bb,des} = 0.055 \text{ in}^2/\text{ft}$  Min.tension reinforcement  $A_{bb,min} = 0.259 \text{ in}^2/\text{ft}$

**PASS - Area of reinforcement provided is greater than minimum area of reinforcement required**

**Rectangular section in shear - Chapter 11**

Factored shear force  $V = 4089 \text{ lb/ft}$   
 Nominal conc.shear strength  $V_c = 13282 \text{ lb/ft}$  Strength reduction factor  $\phi_s = 0.75$   
 Design conc.shear strength  $\phi V_c = 9961 \text{ lb/ft}$   $V / \phi V_c = 0.411$

**PASS - No shear reinforcement is required**

**Rectangular section in flexure - Chapter 10**

Factored bending moment  $M = 15123 \text{ lb\_ft/ft}$   
 Tens.reinforcement provided No.4 bars @ 8" c/c Tens.reinforcement provided  $A_{bt,prov} = 0.295 \text{ in}^2/\text{ft}$   
 Max.reinforcement spacing  $s_{max} = 18 \text{ in}$

*HEEL*

*OK - SEE RIB*

**PASS - Reinforcement is adequately spaced**

Nominal flexural strength  $M_n = 14039 \text{ lb\_ft/ft}$  Strength reduction factor  $\phi_f = 0.9$   
 Design flexural strength  $\phi M_n = 12635 \text{ lb\_ft/ft}$   $M / \phi M_n = 1.197$

**FAIL**

**- Design flexural strength is less than factored bending moment**

Reinforcement by analysis  $A_{bt,des} = 0.354 \text{ in}^2/\text{ft}$  Min.tension reinforcement  $A_{bt,min} = 0.259 \text{ in}^2/\text{ft}$

**PASS - Area of reinforcement provided is greater than minimum area of reinforcement required**

**Rectangular section in shear - Chapter 11**

Factored shear force  $V = 5517 \text{ lb/ft}$   
 Nominal conc.shear strength  $V_c = 14799 \text{ lb/ft}$  Strength reduction factor  $\phi_s = 0.75$   
 Design conc.shear strength  $\phi V_c = 11100 \text{ lb/ft}$   $V / \phi V_c = 0.497$

**PASS - No shear reinforcement is required**

**Check key design**

Depth of section  $h = 12 \text{ in}$

**Rectangular section in flexure - Chapter 10**

Factored bending moment  $M = 928 \text{ lb\_ft/ft}$   
 Tens.reinforcement provided No.4 bars @ 8" c/c Tens.reinforcement provided  $A_{k,prov} = 0.295 \text{ in}^2/\text{ft}$   
 Max.reinforcement spacing  $s_{max} = 18 \text{ in}$

**PASS - Reinforcement is adequately spaced**

Nominal flexural strength  $M_n = 12567 \text{ lb\_ft/ft}$  Strength reduction factor  $\phi_f = 0.9$   
 Design flexural strength  $\phi M_n = 11310 \text{ lb\_ft/ft}$   $M / \phi M_n = 0.082$

**PASS - Design flexural strength exceeds factored bending moment**

Reinforcement by analysis  $A_{k,des} = 0.024 \text{ in}^2/\text{ft}$  Min.tension reinforcement  $A_{k,min} = 0.259 \text{ in}^2/\text{ft}$

**PASS - Area of reinforcement provided is greater than minimum area of reinforcement required**

**Rectangular section in shear - Chapter 11**

Factored shear force  $V = 1737 \text{ lb/ft}$   
 Nominal conc.shear strength  $V_c = 13282 \text{ lb/ft}$  Strength reduction factor  $\phi_s = 0.75$   
 Design conc.shear strength  $\phi V_c = 9961 \text{ lb/ft}$   $V / \phi V_c = 0.174$

**PASS - No shear reinforcement is required**


SEISMIC (LC3)

REF IBC 2009 SECT 1807.2.3

USE 0.7X NOMINAL EARTHQUAKE FORCE, FOS = 1.1

SOS FOR SITE IS 0.30g

SEISMIC LOAD IS INVERTED TRIANGLE:



$$F_E = \frac{3}{8} K_{hE} \gamma H^2$$

$$\gamma = 125 \text{ pcf}$$

$$K_{hE} = \frac{S_{OS}}{2.5} = 0.12 \quad (\text{IBC } 1803.5.12)$$

$$F_E = \frac{3}{8} (.12) (125) \frac{(9.5)^2}{(8.5)^2} = 406 \text{ \#/ft}$$

$$\text{SEISMIC OTM} = 406 (.6) (9.5) = 2071 \text{ ft-\#}$$

REF LCL DESIGN: OTM = 11034 ft-\#

STABILITY M = 22608 ft-\# PG R5

ADD SEISMIC TO LCL FOR LC4:

$$\text{OTM FOS} = \frac{22608}{14557} = 1.55 > 1.1 \text{ OK}$$

$$\text{SLIDING FOS} = \frac{4621 + 5584}{2454 + 0.7(406)9.5} = 1.69 > 1.1 \text{ OK}$$

(CONSERVATIVE - USES 1.0L INSTEAD OF 0.75L)



BEARING PRESSURE

FROM LC1 ANALYSIS:

$$M = \frac{11034}{6900} \text{ ft-#}$$

$$V = \frac{6154}{6900} \text{ #}$$

$$CG = \frac{11034}{6900} = 1.28 \text{ ft} \quad \therefore e = \frac{6 - 1.6}{2} = 1.05 \text{ ft}$$

$> b/6 = 1.33 \text{ ft}$

REF TENG, "FOUNDATION DESIGN" PRENTICE-HALL 1962  
FIG 6-14

$$q_{max} = \frac{Q}{A} \left[ \frac{4B}{3B - 6e} \right]$$

$$= \frac{6900}{4.67} \left[ \frac{4(6.0)}{3(4.67) - 6(1.05)} \right]$$

$$= 1318 \left[ \frac{2.4}{2.5} \right] = 2193 \text{ psf}$$

2760  
2875 IN PROGRAM ✓

ADD SEISMIC MOMENT, RECALCULATE

ADJUST OTM FOR 0.75E

$$\text{SURCHARGE OTM} = 125 \left( \frac{0.75}{0.7} \right)^2 = 4516 \text{ ft-#}$$

$$0.25 M_{LL} = \left\{ \begin{array}{l} \text{REDUCTION} \\ 2894 \end{array} \right\} \left\{ \begin{array}{l} 1410 \\ 1520 \end{array} \right\} \text{ ft-#}$$

$$\text{SEISMIC OTM} = 0.75(7)2071 = 1087 \text{ ft-#}$$


NET INCREASE  
425-#  
+110 ft-#

NEGLECTABLE - BEARING PRESSURE OK

$$\frac{11034 + 110}{11034} = 1.01 \text{ i.e. } 1\% \text{ INCREASE - NEGLECTABLE}$$

WIND (LC4)

$V = 95 \text{ MPH, EXP C}$



WIND OVER TOP OF WALL CREATES A SUCTION FORCE THAT CONTRIBUTES TO OVERTURNING.


FROM ASCE 7-05, SECTION 6.5.15

$F = q_z G C_f A_f \quad G = 0.85, C_f = 1.4$

$q_z = 0.00256 K_z K_{zt} K_d V^2 I$

$K_z = 0.57, K_{zt} = 1.0, K_d = 0.85, I = 1.0$

$q_z = 0.00256 (1.57)(1)(0.85)(95)^2 (1.0)$   
 $= 11.2 \text{ say } 12 \text{ psf.}$



$F = 12(0.85)(1.4)1 = 14.3 \text{ say } 15 \text{ psf.}$

$V_{WIND} = \left\{ 15 \left( \frac{6.5}{5.5} \right) = 16.3 \text{ psf} \right.$

$OTM_{WIND} = 16.3 \left( 3 + \frac{5.5}{2} \right)$

$= 140 \text{ ft-k/ft.}$

LOAD COMBIN  $D + L + 0.75L + 0.75W$

$0.25L = \left\{ \frac{140}{1.25} \text{ ft-k} \right\}$  (FROM LC5 ANALYSIS)  
 $> 0.75W$

REDUCED IN LL OFFSETS WIND OTM. WALL OK

REINFORCING

MODIFY REINF AS DESIGNED BY PROGRAM / RECHECK  
ACT CODE.

WALL

PRIMARY REINF #6 @ 12" - OK

$$\phi M_n = 1650 \text{ FT}\cdot\text{K}/\text{FT. (R11)}$$

CHECK BASE DEVELOPMENT

$$l_{dn} = 19d_b \times 0.7 = 10''$$

AVAILABLE EMBED

$$= 12'' - 3'' - 2(1/2) = 8'' \text{ @ } 20''$$

PER ACT 318  $\phi \geq 12.5(d)$   $\therefore$  100% DEVELOPED


~~PROVIDE DEVELOPMENT~~

$$\therefore \phi M_n = \frac{8}{10} (1650) \triangle$$

$$= 13,200 \text{ FT}\cdot\text{K}/\text{FT.}$$

> MAX LOADING

$$M = \frac{10712}{14609} \text{ FT}\cdot\text{K}/\text{FT. (LC2) OK.}$$



FLEXURAL SIDE

$$\rho = .0033$$

$$d = 12 - 2 - 3/4 - 3/8 = 8 7/8''$$

say 9''

$$A_{s,MIN} = .0033 (9)(12)$$

$$= 0.36 \text{ IN}^2/\text{FT. OK.}$$

EXPOSED FACE:  $A_{s,MIN} = .0015 (12)(12) = 0.22 \text{ IN}^2$  TOTAL


#4 @ 12" FRONT FACE ADDS 0.20 TO 0.44

OK

HORIZ:  $A_{s,MIN} = .0020 (12)(12) = 0.29 \text{ IN}^2/\text{FT.}$

#4 @ 12" HORIZ EF 0.40  $\text{IN}^2/\text{FT. OK}$

CONSIDER SPLICING #6 MAIN BSR




#6  $l_d = 38d_b = 28.5" \text{ in.}$

#4  $l_d = 38(1.5) = 19" \times 1.3 \text{ (SPLICE)} = 24.7 \text{ say } 24"$

SAVE  $\frac{70(1.502)}{12} = 8.76 \text{ \#/FT.}$

ADD  $\frac{(70+24)(.67)}{12} = 5.25$   
 $3.5 \text{ \#/FT. SWINGS}$




$39(\frac{3}{5}) = 195$   
 $\frac{195}{5} = 117 \text{ \#/FT}$

$M_{ue} \frac{42}{30} = 1.6 \frac{(125)(\frac{5}{2})^2}{2} + 1.6 (117) \frac{5}{2} (\frac{5}{3}) = 1100 \text{ ft-\#/ft.}$

$F = \frac{(9)^2}{1000} = 0.081$ ;  $K_m = \frac{M_u}{F} = 14.56$ ;  $a_m = 4.45$

$l_s = \frac{M_u}{a_m} = \frac{1100}{9(4.45)} = 0.10 \text{ in}^2$   
 $\# 4 @ 12" \text{ O.C.}$   
 $(0.2 \text{ in}^2/\text{ft})$

MAT.



PROGRAM DEFAULT VALUE IS #4 @ 8"

#5  $l_d = 38 \left( \frac{.75}{1.675} \right) = 28.5 < 22"$   
 AVAILABLE  
 ADD STD HOOK

OTHER HOOKS SHOWN ON PROGRAM NOT REQUIRED -  $l_d$  IS ADEQUATE

$A_{smin} = .003(12)(8.5) = 0.31 \text{ IN}^2/\text{FT.}$   
 #5 @ 12"

LC 1

$M_u = 12189 \text{ FT-LB}$   
 $M_u = 12189 \text{ FT-LB}$

$\phi M_n = 12635 \times \frac{8}{12} = 8423 \text{ FT-LB} - \text{OK}$

LC 2

$M_u = 15123 \text{ FT-LB}$   
 $M_u = 15123 \text{ FT-LB} > \phi M_n = 12635 \text{ FT-LB}$

RECHECK  $\phi M_n$

$d = 12 - 2 - \frac{1}{2} - \frac{1}{4} = 9\frac{1}{4}"$

$F = \frac{(9.25)^2}{1000} = 0.0855$

$K_M = \frac{M_u}{F} = \frac{15123}{0.0855} = 177$ ;  $a_M = 4.37$

$A_s \text{ REQ'D} = \frac{15123}{9.25(4.42)} = 0.37 \text{ IN}^2/\text{FT}$   
 $= 0.22 \text{ IN}^2/\text{FT}$


USE #5 @ 12" TOP BAR

0.35 REQ'D BY PROGRAM

$A_s = (0.37 \text{ IN}^2/\text{FT} > \#4 @ 8" (0.30 \text{ IN}^2/\text{FT}))$

PROVIDE STD HOOK @ TOE ✓

$l_d = 19 \left( \frac{.75}{1.675} \right) (1.7) = 10.0 < 22" \text{ AVAILABLE}$   
 OK.



**BUCKS COUNTY RECORDER OF DEEDS**

55 East Court Street  
Doylestown, Pennsylvania 18901  
(215) 348-6209

Instrument Number - 2006062298

Recorded On 6/6/2006 At 10:43:25 AM

\* Total Pages - 3

\* Instrument Type - PLANS

Invoice Number - 140829

User - NMS

\* Grantor - U S S R E

\*

\* Customer - U S S REAL ESTATE

**\* FEES**

RECORDING FEES \$50.50

TOTAL \$50.50



This is a certification page

**DO NOT DETACH**

This page is now part  
of this legal document.

**RETURN DOCUMENT TO:**  
U S S REAL ESTATE

I hereby CERTIFY that this document is  
recorded in the Recorder of Deeds Office  
of Bucks County, Pennsylvania.



*Edward R. Gudknecht*  
Edward R. Gudknecht  
Recorder of Deeds

\* - Information denoted by an asterisk may change during  
the verification process and may not be reflected on this page.

Book: 340 Page: 61

